LISTING SERVICE

LISTING No.   7150-0559:136   Page 1 of 1

CATEGORY: Boxes/Pull Stations

LISTEE: Silent Knight Security, 7550 Meridian Circle, Maple Grove, MN 55369
Contact: Brian Foltz *(763) 493-6400

DESIGN: Model PS-SKSA and SD500-PS fire alarm pull boxes. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 30 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm pull station use with separately listed compatible fire alarm control units. For indoor use only.

10-26-2000

This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 15, 2003**   *Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, *Senior Deputy*
Program Manager